



NOTES:

1. ALL OUTSIDE AND INSIDE CORNERS REQUIRE TWO COMPLETE CORNER APPLICATIONS OF PEEL & STICK UNCURED EPDM FLASHING AS PER [DETAILS WBRC-15.](#)
2. WIDTH OF JOINT SHALL BE A MINIMUM OF 3/4" (19mm) AND SHALL NOT EXCEED 2" (51mm) WHEN WEATHERBOND EXPANSION JOINT SUPPORT IS USED.
3. ALL VERTICAL FIELD SPLICES AT THE BASE OF A WALL OR CURB MUST BE OVERLAID WITH A PEEL & STICK T-JOINT COVER OR A 6"X6" (152mm X 152mm) SECTION OF PEEL & STICK UNCURED EPDM FLASHING CENTERED OVER THE FIELD SPLICE. PROJECTS USING 90-MIL MEMBRANE. ALL VERTICAL SPLICES MUST BE OVERLAID WITH A T-JOINT COVER AND COVERED WITH A 12"X12" (305mm x 305mm) PEEL & STICK UNCURED EPDM FLASHING PIECE OR T-JOINT COVER. BOTH LAYERS SHALL BE CENTERED AND SEALED WITH CONTINUOUS LAP SEALANT. REFER TO [DETAIL WBRC-2.3.](#)
4. ON MECHANICALLY FASTENED SYSTEMS, HPWX FASTENERS AND POLYMER SEAM PLATES ARE REQUIRED OVER STEEL DECKS.
5. EPDM PRIMER MUST BE APPLIED TO BACK SIDE OF DECK MEMBRANE PRIOR TO COMPLETING SPLICE TO PEEL & STICK RPS.



DECK-TO-WALL EXPANSION JOINT

- EPDM MEMBRANE
- APPROVED SUBSTRATE
- SEE NOTE

EPDM ROOFING SYSTEM

WBRC-3.2