



NOTES:

1. SEPARATION SHALL BE PROVIDED BETWEEN PVC MEMBRANE AND ASPHALTIC SHINGLES. REFER TO SPECIFICATIONS.
2. ON MECHANICALLY ATTACHED SYSTEMS, HPWX FASTENERS AND PLATES ARE REQUIRED OVER STEEL OR WOOD DECKS.
3. APPROXIMATELY 1/8" (0.5cm) DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF WEATHERBOND REINFORCED TPO MEMBRANE.



TPO/PVC TIE-IN TO SHINGLED ROOF

	WEATHERBOND THERMOPLASTIC REINFORCED MEMBRANE
	APPROVED SUBSTRATE
	SEE NOTE

THERMOPLASTIC ROOFING SYSTEM

WBPC-13.6